



# CLEVIS HANGER WITH WELDED SHIELD NEFCO FIG #N260WS

411 BURNHAM ST.  
P.O. BOX 280186  
EAST HARTFORD, CT 06108  
TEL (860) 289-0285 FAX (860) 282-1487  
TOLL FREE 1-800-969-0285

EMPIRE INDUSTRIES, INC. FIG. # 11WS  
ERICO FIG. #403

**MATERIAL:**  CARBON STEEL


**FINISH:**  BLACK  ELECTRO-GALVANIZED  PAINTED

**SERVICE:** DESIGNED FOR THE SUSPENSION OF STATIONARY INSULATED PIPE LINES. INSULATION PROTECTION SHIELD IS SPOT WELDED IN PLACE.

**APPROVALS:** FEDERAL SPECIFICATION WW-H-171 (TYPE 1)\* MANUFACTURERS STANDARDS SOCIETY ANSI/MSS SP58 (TYPE 1)\* INSTALL IN ACCORDANCE WITH ANSI/MSS SP69.\*(PRINCIPAL COMPONENT)

**ORDERING:** SPECIFY HANGER SIZE NUMBER AND FIGURE NUMBER.

**NOTES:** TO DETERMINE PROPER HANGER SIZE USE HANGER SELECTION GUIDE BELOW. UPPER LOCKNUT MUST BE TIGHTENED SECURELY TO ASSURE PROPER HANGER PERFORMANCE.



WITH WELDED SHIELD

PIPE SIZE	HANGER SIZING GUIDE THICKNESS OF PIPE INSULATION					
	1/2"	1"	1 1/2"	2"	2 1/2"	3"
1/2	1 1/2	2 1/2	3 1/2	5	6	7
3/4	2	3	3 1/2	5	6	7
1	2	3	4	5	6	7
1 1/4	2 1/2	3 1/2	4	5	6	7
1 1/2	2 1/2	3 1/2	5	6	7	8
2	3	4	5	6	7	8
2 1/2	3 1/2	5	6	7	8	10
3	4	5	6	7	8	10
3 1/2	5	6	7	8	10	10
4	5	6	7	8	10	10
5	6	7	8	10	10	12
6	7	8	10	10	12	12
8	10	10	12	12	14	16
10	12	12	14	16	16	18
12	14	16	16	18	18	20
14	16	16	18	18	20	20
16	18	18	20	20	24	24

SUBMITTAL INFORMATION		
CUSTOMER:	APPROVAL STAMP	
PROJECT NAME:		
PROJECT NUMBER:		SECTION:
PARAGRAPH:		OTHER:

REV: A

2008